

WVU DESIGN GUIDELINES & CONSTRUCTION STANDARDS
DIVISION 23 – HEATING, VENTILATION, AND AIR CONDITIONING

SECTION 232301 - REFRIGERANT

PART 1 - GENERAL

- 1.1 Any deviance from the following instructions must be approved during design by WVU Facilities Management project manager.

PART 2 - PRODUCTS

- 2.1 If the pertinent type and size equipment is available with zero ozone depletion refrigerants, then that is what shall be specified. It shall also be noted in the drawing schedules. If not, then the most environmentally friendly refrigerant shall be specified.

PART 3 – EXECUTION

N/A

END OF SECTION 232301