

WVU DESIGN GUIDELINES & CONSTRUCTION STANDARDS
DIVISION 08 – OPENINGS

SECTION 088000– GLAZING

PART 1: GENERAL

1.1 Scope of Standard

- A. This standard provides general guidance concerning the specific preferences for transparent and translucent glass for general and special purpose applications.
- B. This standard also provides general guidance concerning the specific preferences for etched, stained, beveled, sandblasted, or carved glass, in historic buildings.
- C. Project conditions and requirements vary, thus precluding the absolute adherence to the items identified herein in all cases. However, unless there is adequate written justification, it is expected that these guidelines will govern the design and specifications.

1.2 Quality Control

- A. In no instance will glass with a film coating be acceptable.
- B. Wire glass: Use of this type product is not preferred. This type of glass in doors and walls will be in metal frames that wrap walls and doors.
- C. Historic Glass is to be replaced with a reproduction of like kind. In other instances, consult with the Project Manager.

1.3 General Requirements

- A. Other: For exterior glazing, use of clear low E insulated glass is preferred. No reflective glass is to be used. If shading is necessary refer all information to Project manager for discussion guidance.
- B. Manufacturers stamp is to be provided on all glass required by code to be heat tempered , heat strengthened or safety.
- C. Asbestos: In no instance will any product containing asbestos be acceptable for use.
- D. Lead: In no instance will any product containing lead be acceptable for use.

PART 2: PRODUCTS – NOT USED

PART 3: EXECUTION – NOT USED

END OF SECTION 088000