

SECTION 092900– INTERIOR GYPSUM BOARD

PART 1: GENERAL

1.1 Scope of Standard

- A. This standard provides general guidance concerning the specific preferences for unfinished and pre-finished gypsum board, gypsum and cementitious backing board, metal framing, trim, and accessories
- B. Project conditions and requirements vary, thus precluding the absolute adherence to the items identified herein in all cases. However, unless there is adequate written justification, it is expected that these guidelines will govern the design and specifications.

1.2 Related Standards

- A. Floor to floor full height assemblies: Refer to Section 072100 of this document.
- B. Fire Stopping: Refer to section 078413 of this document for locations where this type of assembly is to be constructed.

1.3 Reference Standards

- A. Refer to UL rated assemblies manual for expansion and construction required to be rated by code.
- B. Refer to US Gypsum Standards for control joints.

1.4 Quality Control

- A. Drywall – 5/8” thickness or greater, fire rated, type X long edge tapered
5/8” thickness or greater, moisture resistant in moisture prone locations
- B. Plumb: All assemblies shall have a tolerance of 1/8” in 10’ maximum.
- C. Trim: All outside corners shall be floated with metal trim.
- D. Interior corners and panel joints shall be taped and floated.
- E. Finish: See section 099100 Painting

1.5 General Requirements

- A. Asbestos: In no instance will any product containing asbestos be acceptable.
- B. Provide Concrete Board for walls and ceilings in moisture prone areas, such as restrooms, janitor closets, and wet labs.

WVU DESIGN GUIDELINES & CONSTRUCTION STANDARDS
DIVISION 09 – FINISHES

PART 2: PRODUCTS – NOT USED

PART 3: EXECUTION – NOT USED

END OF SECTION 092900