

**WVU DESIGN GUIDELINES & CONSTRUCTION STANDARDS**  
**DIVISION 10 - SPECIALITIES**

---

**SECTION 102113 – TOILET COMPARTMENTS**

**PART ONE: GENERAL**

1.1 Scope of Standard

- A. This standard provides general guidance concerning the specific preferences for toilet compartments. All product specifications, accessory items, colors, finishes, applications and details are to be reviewed and approved by the WVU project representative prior to the final development of the Construction Documents.
- B. Project conditions and requirements vary, thus precluding the absolute adherence to the items identified herein in all cases. However unless adequate written justification is provided, then it is expected that these guidelines will govern the design and specifications.

1.2 Quality Control

A. Toilet Compartments

- 1. Standard ceiling mounted, stamped or textured stainless steel toilet partitions are preferred for high-use student areas and phenolic stalls are acceptable in other areas. Other materials used only with prior approval. Baked enamel is not preferred. Anchors and fasteners: Vandal type screw anchors, toggle bolts, hollow wall anchors or other approved type to suit construction on which items are hung. Wood, lead and plastic plugs are prohibited Door latches and pulls: Specify slide latches and pulls for out-swinging doors.
- 2. Ceiling mounted partitions shall be braced appropriately to minimize movement.
- 3. Minimal recommended spacing is 3 ft. width and the depth shall be 5'-0".
- 4. All toilet stalls designated usable by individuals with disabilities shall be 60"x60". The water closet must be located 18" (inches) from the wall or partition. A fraction of 1/4" (inches) either way is an approved installation tolerance. A memorandum describing any departures for ADAAG and/or WVU standards for accessibility shall be included with the Construction Documents and a copy provided to the ADA Coordinator for WVU.
- 5. Full stall door (the height of the partition) shall be used. All doors shall swing inward.
- 6. Each compartment shall have a coat hook and shelf as necessary.
- 7. Modesty partition shall be provided between wall hung urinals.
- 8. All toilet compartments must comply with ADA standards.

END OF SECTION 102113